

五領川浄化センター平常試験結果

日	曜日	天候	気温(℃) 最高/最低		処理水量 (m3)	放流水量 (m3)	透視度(cm)					pH(-)					DO(mg/l)					COD(mg/l)					水温(℃)					反応タンク								
							沈砂流入	タンク流入	反応タンク	終沈	放流	沈砂流入	タンク流入	反応タンク	終沈	放流	沈砂流入	タンク流入	反応タンク	終沈	放流	沈砂流入	タンク流入	反応タンク	終沈	放流	沈砂流入	タンク流入	反応タンク	終沈	放流	MLSS (mg/l)	RSSS (mg/l)	T1 SV (%)	T2 SV (%)	T3 SV (%)	T1 SVI	T2 SVI	T3 SVI	空気倍率
1	水	☉			4,573	5,050																														4.4				
2	木	☉			4,552	5,024																													4.4					
3	金	☉			4,967	5,446																													4.1					
4	土	*			4,931	5,231																													4.1					
5	日	○			5,038	5,203																													4					
6	月	●	8.0	2.0	5,233	5,604	3	8	32	101	101	7.4	6.9	6.7	6.7	6.8	1.2	0.0	0.1	3.7	4.1						14.8	15.6	15.2	14.4	14.8	2,900	7,500	97	96	94	334	331	303	3.9
7	火	●	8.0	3.0	5,656	6,042	5	9	32	101	101	7.3	6.8	6.8	6.8	6.8	2.6	1.0	0.2	1.5	3.2						14.7	15.1	15.4	14.8	14.3			95	97	96				3.6
8	水	*	5.0	1.0	6,260	6,636	6	8	32	101	101	7.3	6.9	6.7	6.9	7.0	1.7	0.0	0.2	3.8	4.6						15.9	15.8	16.1	15.4	14.7	2,600	8,000	97	96	95	373	356	339	3.3
9	木	*	4.0	0.0	6,956	7,229	7	10	28	101	101	7.2	7.0	6.6	6.7	6.7	4.5	2.0	0.1	4.2	5.2	83	51	8.8	7.6	7.8	14.4	14.2	14.8	13.9	13.5			95	95	94				3
10	金	*	3.0	-1.0	5,959	5,612	7	10	32	101	101	7.4	7.1	6.5	6.7	6.6	4.1	0.9	0.2	4.1	4.7						13.8	13.6	14.1	13.0	13.0	1,900	7,700	97	96	96	511	384	369	3.4
11	土	☉			5,138	5,574																														4				
12	日	☉			4,914	5,361																														4.2				
13	月	☉			5,879	6,219																														3.5				
14	火	●	7.0	2.0	6,030	6,299	6	9	32	101	61	7.6	7.0	6.6	6.8	6.5	3.8	0.7	0.2	6.8	6.5						13.3	13.9	14.0	13.5	13.4			98	98	96				3.6
15	水	●	7.0	1.0	7,355	7,476	6	7	32	101	40	7.5	6.9	6.6	6.6	6.6	4.3	1.7	0.3	3.0	4.2						13.5	13.8	14.5	13.5	14.2	2,200	8,300	95	96	97	432	417	441	3.2
16	木	●	5.0	0.0	6,070	6,322	7	13	32	101	25	7.4	7.0	6.5	6.6	6.7	3.5	1.2	2.2	3.3																				

[illegible]