

五領川浄化センター平常試験結果

日	曜日	天候	気温(℃) 最高/最低		処理水量 (m3)	放流量 (m3)	透視度(cm)					pH(-)					DO(mg/l)					COD(mg/l)					水温(℃)					反応タンク									
							沈砂流入	タンク流入	反応タンク	終沈	放流	沈砂流入	タンク流入	反応タンク	終沈	放流	沈砂流入	タンク流入	反応タンク	終沈	放流	沈砂流入	タンク流入	反応タンク	終沈	放流	沈砂流入	タンク流入	反応タンク	終沈	放流	MLSS (mg/l)	RSSS (mg/l)	T1 SV (%)	T2 SV (%)	T3 SV (%)	T1 SVI	T2 SVI	T3 SVI	空気倍率	
1	土	○			4,579	5,208																															4.5				
2	日	☉			4,566	5,155																														4.5					
3	月	☉	10.0	1.0	4,844	5,381	5	7	25	101	87	7.3	6.9	6.5	6.6	6.5	2.1	0.0	0.4	3.0	4.0							15.6	14.9	15.3	15.0	14.7	2,500	6,700	98	98	98	392	363	350	4.2
4	火	*	3.0	0.0	6,049	6,357	6	8	23	101	101	7.5	6.7	6.5	6.6	6.5	1.8	0.1	0.3	3.3	3.8							14.9	14.6	15.4	14.7	14.9			98	98	97				3.3
5	水	*	2.0	-1.0	6,161	6,486	4	12	22	101	101	7.3	6.7	6.3	6.5	6.4	2.9	1.2	0.3	3.7	4.5							14.2	14.5	15.2	14.5	14.6	2,100	6,900	98	98	97	467	467	422	3.2
6	木	*	3.0	-2.0	5,905	6,316	7	8	32	101	70	7.2	6.9	6.2	6.4	6.4	3.7	1.2	0.4	1.6	3.1							13.5	13.5	14.0	13.8	12.7			97	97	98				3.4
7	金	☉	4.0	-1.0	5,619	6,068	5	10	28	101	78	7.4	6.9	6.3	6.4	6.5	3.4	1.6	0.4	3.3	4.5							13.9	13.3	13.5	13.5	13.1	2,200	6,500	98	97	95	445	422	396	3.5
8	土	*			5,246	5,737																															3.8				
9	日	*			5,347	5,802																															3.8				
10	月	☉	5.0	0.0	5,711	6,065	6	10	32	101	101	7.4	6.8	6.2	6.4	6.5	3.5	0.1	0.4	2.9	3.9							12.8	13.4	13.8	12.9	12.9	2,300	6,900	97	98	98	422	408	392	3.5
11	火	○			5,619	6,055																															3.6				
12	水	○	11.0	-2.0	5,702	6,098	5	10	32	101	101	7.2	6.8	6.3	6.5	6.5	4.6	2.6	0.3	3.6	4.7	118	52	5.6	8.0	9.6	12.9	13.5	13.7	12.4	12.7	2,300	6,800	96	96	96	417	400	384	3.5	
13	木	☉	8.0	1.0	6,355	6,673	7	11	32	101	65	7.4	6.6	6.5	6.5	6.2	5.1	2.9	0.1	2.9	4.0							12.3	12.7	13.3	13.6	13.4			95	95	97				3.1
14	金	○	8.0	0.0	5,437	5,841	6	8	25	101	70	7.4	6.6	6.1	6.2	6.4	3.6	1.5	0.4	4.1	3.4							13.6	13.3	13.7	12.6	12.5	2,200	5,500	96	97	97	436	404	388	3

[illegible]