

五領川浄化センター平常試験結果

日	曜日	天候	気温(℃) 最高/最低	処理水量 (m3)	放流量 (m3)	透視度(cm)					pH(-)					DO(mg/l)					COD(mg/l)					水温(℃)					反応タンク									
						沈砂 流入	タンク 流入	反応 タンク	終沈	放流	沈砂 流入	タンク 流入	反応 タンク	終沈	放流	沈砂 流入	タンク 流入	反応 タンク	終沈	放流	沈砂 流入	タンク 流入	反応 タンク	終沈	放流	沈砂 流入	タンク 流入	反応 タンク	終沈	放流	MLSS (mg/l)	RSSS (mg/l)	T1 SV (%)	T2 SV (%)	T3 SV (%)	T1 SVI	T2 SVI	T3 SVI	空気 倍率	
1	金	●	11.0	3.0	6,943	5,548	5	6	32	101	101	7.6	7.0	6.9	6.9	7.0	2.1	0.7	0.1	3.1	3.2						15.5	15.5	15.7	14.9	15.3	3,000	9,200	92	92	91	307	297	294	2.9
2	土	●			6,852	5,229																															2.9			
3	日	○			6,770	5,196																														3				
4	月	●	11.0	2.0	7,146	5,247	4	6	32	101	101	7.6	7.0	6.9	6.8	6.7	1.9	0.7	0.2	3.3	4.0						15.0	15.0	15.4	14.3	14.5	3,200	9,000	94	93	93	294	291	291	2.9
5	火	◎	8.0	2.0	7,156	4,991	5	8	32	101	101	7.7	7.0	6.9	6.8	6.8	2.3	0.5	0.2	3.0	3.6						14.7	15.2	15.2	14.0	14.3			94	93	93				2.9
6	水	◎	8.0	3.0	7,135	4,939	6	11	28	101	101	7.4	7.0	6.8	6.9	7.0	3.4	2.5	2.3	3.4	3.9	123	70	25	8.0	5.0	15.0	15.4	15.6	14.9	15.2	3,000	8,900	93	93	90	310	310	300	2.9
7	木	○	9.0	3.0	6,696	4,606	5	10	32	101	101	7.7	7.3	6.8	6.9	7.7	2.1	1.8	0.1	2.5	3.6						16.0	16.3	16.2	15.9	16.1			93	94	93				3.1
8	金	◎	10.0	0.0	6,679	4,598	5	8	32	101	101	7.9	7.1	7.0	6.9	6.8	2.2	1.1	0.2	2.7	3.5						15.3	14.8	15.0	13.8	13.5	3,100	8,500	94	93	94	303	291	294	3.1
9	土	◎			6,637	4,568																															3.1			
10	日	*			6,983	4,863																															3			
11	月	○	13.0	-1.0	6,667	4,619	4	7	32	101	101	7.7	7.3	6.7	6.8	6.7	4.3	2.4	0.1	3.4	4.4						14.6	14.7	15.2	14.0	14.0	3,200	8,800	94	93	93	294	282	282	3.1
12	火	●	9.0	5.0	7,631	5,310	3	10	32	101	101	7.6	7.2	6.7	6.9	6.8	3.7	3.0	0.2	3.1	3.9						14.8	15.5	15.8	14.7	15.1			92	92	91				2.7
13	水	○	10.0	3.0	7,145	4,929	5	7	32	101	101	7.8	7.0	6.9	6.7	6.9	5.1	3.3	0.2	3.6	3.2						14.0	15.1	15.3	14.6	14.9	3,000	9,200	94	93	94	313	310	313	2.9
14	木	○	14.0	1.0	6,684	4,586	4	8	32	101	101	7.6	7.1	6.7	6.8	6.7	1.7	0.9	0.2	2																				

[illegible]