

五領川浄化センター平常試験結果

日	曜日	天候	気温(℃) 最高/最低		処理水量 (m3)	放流水量 (m3)	透視度(cm)					pH(-)					DO(mg/l)					COD(mg/l)					水温(℃)					反応タンク									
							沈砂 流入	タンク 流入	反応 タンク	終沈	放流	沈砂 流入	タンク 流入	反応 タンク	終沈	放流	沈砂 流入	タンク 流入	反応 タンク	終沈	放流	沈砂 流入	タンク 流入	反応 タンク	終沈	放流	沈砂 流入	タンク 流入	反応 タンク	終沈	放流	沈砂 流入	タンク 流入	反応 タンク	終沈	放流	MLSS (mg/l)	RSSS (mg/l)	T1 SV (%)	T2 SV (%)	T3 SV (%)
1	水	☉	17.0	12.0	7,148	4,687	4	8	27	101	101	7.5	6.8	7.1	7.1	7.1	1.0	0.5	1.8	2.6	3.5						19.1	19.5	19.6	19.4	19.5	2,900	8,400	95	96	94	328	331	313	2.8	
2	木	○	18.0	10.0	7,019	4,622	5	7	32	101	101	7.6	6.9	7.0	7.1	7.1	0.4	0.4	1.4	2.7	3.5						19.2	19.7	19.8	19.4	19.5			96	95	94				2.9	
3	金	○			6,585	4,360																																	3.1		
4	土	○			6,417	4,226																																	3.1		
5	日	○			6,345	4,144																																	3.2		
6	月	○			6,510	4,220																																	3		
7	火	●	22.0	16.0	7,328	4,803	2	4	32	101	101	7.7	6.9	7.1	7.1	7.1	0.7	1.0	1.8	2.5	7.1						19.8	19.8	19.9	19.4	19.3			96	96	94				2.7	
8	水	☉	15.0	10.0	7,048	4,591	4	6	32	101	101	7.9	6.9	7.1	7.1	7.1	0.6	1.6	0.4	2.5	3.3	120	69	12	11	9.8	19.6	20.2	20.3	19.8	19.7	3,000	7,600	95	94	95	317	313	317	2.9	
9	木	☉	16.0	10.0	7,055	4,643	2	6	32	101	101	7.4	6.8	7.0	7.1	7.1	0.5	0.7	1.4	3.4	4.3						19.4	19.3	19.3	18.9	18.9			95	93	94				2.9	
10	金	○	25.0	6.0	6,839	4,544	4	8	32	101	101	7.6	7.0	6.9	7.1	7.0	1.0	1.8	1.3	2.9	3.7						18.9	20.0	20.1	18.9	18.9	2,900	8,300	94	94	94	324	313	313	3	
11	土	○			6,556	4,327																																	3.1		
12	日	☉			6,684	4,357																																	3		
13	月	●	18.0	11.0	8,230	5,540	3	6	32	101	101	7.3	6.9	6.9	7.0	7.0	2.0	2.1	1.3	2.4	3.2						18.8	19.4	20.2	20.0	19.8	2,500	7,400	94	94	90	376	362	360	2.4	
14	火	○	22.0	9.0	7,274	4,796	5	10	32	101	101	7.6	6.8	7.0	7.1	7.0	1.2	2.4	0.1	2.7	3.2						19.1	19.8	20.0	19.5	19.6			96	96	93				2.8	
15	水	○	26.																																						

[illegible]