

五領川浄化センター平常試験結果

日	曜日	天候	気温(℃) 最高/最低		処理水量 (m3)	放流水量 (m3)	透視度(cm)					pH(-)					DO(mg/l)					COD(mg/l)					水温(℃)					反応タンク								
							沈砂流入	タンク流入	反応タンク	終沈	放流	沈砂流入	タンク流入	反応タンク	終沈	放流	沈砂流入	タンク流入	反応タンク	終沈	放流	沈砂流入	タンク流入	反応タンク	終沈	放流	沈砂流入	タンク流入	反応タンク	終沈	放流	MLSS (mg/l)	RSSS (mg/l)	T1 SV (%)	T2 SV (%)	T3 SV (%)	T1 SVI	T2 SVI	T3 SVI	空気倍率
1	月	●	26.0	22.0	7,927	7,229	5	5	28	85	15	7.3	6.8	6.9	7.0	6.8	1.3	0.1	0.6	3.1	3.6						23.3	23.5	23.7	23.5	23.8	2,300	6,000	96	96	90	417	384	429	3
2	火	◎	28.0	21.0	6,418	5,791	5	10	28	89	95	7.4	6.7	6.8	6.9	6.8	0.0	0.1	0.7	3.3	3.9						23.4	24.0	24.3	23.7	23.7			93	95	90				3.9
3	水	◎	34.0	22.0	6,470	5,939	6	11	23	96	96	7.7	6.9	6.9	7.0	7.0	0.1	1.8	0.3	3.5	3.8	95	49	15	9.4	8.8	23.3	23.8	24.2	24.1	24.1	2,200	6,800	90	92	85	409	400	354	3.8
4	木	◎	31.0	25.0	6,176	5,537	5	10	30	101	96	7.4	6.9	6.9	7.0	6.9	0.2	0.7	0.3	3.1	3.3						23.9	24.8	25.0	24.6	24.7			94	95	91				4
5	金	○	35.0	24.0	5,823	5,179	5	11	26	101	101	7.4	6.9	6.9	7.0	6.9	0.0	0.1	0.1	5.3	4.0						24.2	25.0	25.0	24.8	24.8	2,400	5,400	90	93	88	375	358	338	4.2
6	土	●			7,377	6,630																																	3.3	
7	日	○			5,999	5,292																																	4.1	
8	月	◎	32.0	26.0	5,926	5,052	5	9	32	101	101	7.3	6.8	6.9	7.0	6.9	0.0	0.1	0.0	3.5	4.2						24.3	25.6	25.5	25.3	25.3	2,400	5,400	90	92	87	375	354	348	4.1
9	火	◎	31.0	25.0	5,978	5,120	5	11	32	101	101	7.3	6.7	6.9	6.9	6.9	0.1	0.2	0.2	2.7	3.3						24.1	25.1	25.6	25.1	25.2			87	90	84				4.1
10	水	◎	29.0	24.0	6,296	5,352	5	9	32	101	101	7.4	6.9	6.9	7.1	6.9	0.2	0.1	0.8	3.5	4.0						24.1	24.7	24.8	24.5	24.6	2,400	5,400	85	94	84	354	362	336	3.9
11	木	●	26.0	22.0	8,061	7,063	3	7	19	101	101	7.2	7.0	7.0	7.1	7.0	0.1	0.2	0.8	3.2	4.1						24.4	24.4	24.9	24.6	24.6			80	88	75				3
12	金	●	28.0	22.0	6,559	5,610	4	8	32	101	101	7.5	7.0	6.8	6.9	6.8	0.1	0.4	0.9	3.4	4.5						23.9	24.1	24.4	23.9	23.9	2,300	5,500	88	90	80	383	360	348	3.7
13	土	○			5,973	5,029																																	4.1	
14	日	●			5,987	4,883																																		

[illegible]