

五領川浄化センター平常試験結果

日	曜 日	天 候	気温(℃) 最高/最低		処理水量 (m3)	放流水量 (m3)	透視度(cm)					pH(-)					DO(mg/l)					COD(mg/l)					水温(℃)					反応タンク								
							沈砂 流入	タンク 流入	反応 タンク	終沈	放流	沈砂 流入	タンク 流入	反応 タンク	終沈	放流	沈砂 流入	タンク 流入	反応 タンク	終沈	放流	沈砂 流入	タンク 流入	反応 タンク	終沈	放流	沈砂 流入	タンク 流入	反応 タンク	終沈	放流	MLSS (mg/l)	RSSS (mg/l)	T1 SV (%)	T2 SV (%)	T3 SV (%)	T1 SVI	T2 SVI	T3 SVI	空気 倍率
1	木	○	34.0	23.0	5,540	5,037	4	9	24	101	101	7.4	6.9	7.0	7.0	7.0	0.0	0.3	0.0	2.3	3.4						25.4	26.4	26.5	26.0	26.1			89	91	87				4.5
2	金	○	36.0	24.0	5,426	4,933	4	8	30	101	101	7.3	7.0	7.0	7.1	7.0	0.1	1.7	0.0	3.5	4.1						25.9	26.7	26.9	26.5	26.5	2,400	5,000	90	89	90	375	342	360	4.7
3	土	○			5,225	4,750																																5		
4	日	○			5,398	4,908																																4.9		
5	月	◎	32.0	25.0	5,597	5,089	4	7	27	101	101	7.1	6.8	6.9	7.1	7.0	0.0	0.2	0.0	3.5	4.1						26.5	27.3	27.7	27.1	27.0	2,400	4,900	89	92	86	371	368	344	4.4
6	火	○	32.0	25.0	5,423	4,930	4	7	28	101	101	7.3	6.9	7.0	7.0	7.0	0.1	0.4	0.0	2.1	3.1						26.1	27.6	27.6	27.0	27.3			91	93	89				4.5
7	水	○	32.0	25.0	5,377	4,889	5	8	32	101	101	7.3	6.9	6.9	7.1	7.1	0.1	0.2	0.0	3.4	4.3						26.4	27.2	27.5	27.0	27.4	2,600	5,300	91	91	90	350	325	333	4.5
8	木	○	33.0	25.0	5,364	4,877	4	8	21	101	101	7.5	7.0	7.0	7.1	7.1	0.1	0.3	0.0	3.2	3.7	95	53	27	7.6	7.8	26.0	26.6	26.8	26.6	26.5			93	92	89				4.6
9	金	○	32.0	23.0	5,368	4,880	5	9	25	101	101	7.3	6.9	7.0	7.1	7.0	0.1	0.2	0.0	3.2	3.7						26.0	26.7	27.0	26.6	26.8	2,300	5,100	94	94	89	409	362	330	4.9
10	土	○			5,168	4,699																																5.6		
11	日	○			5,127	4,661																																5.6		
12	月	◎			5,212	4,739																																5.5		
13	火	○	34.0	24.0	5,432	4,939	5	9	25	101	101	7.0	6.9	6.9	7.0	7.0	0.1	0.1	0.0	3.8	4.7						26.4	27.1	27.2	26.8	26.7			91	92	90				4.8
14	水	○	34.0	26.0	5,264	4,786	5	7	28	101	101	7.3	6.9	7.0	7.2	7.2	0.0	0.2	0.1	3.6	4.4						26.2	27.3	27.5	27.3	27.4	2,600	5,300	93	95					

[illegible]