

五領川浄化センター平常試験結果

日	曜日	天候	気温(℃) 最高/最低		処理水量 (m3)	放流水量 (m3)	透視度(cm)					pH(-)					DO(mg/l)					COD(mg/l)					水温(℃)					反応タンク									
							沈砂流入	タンク流入	反応タンク	終沈	放流	沈砂流入	タンク流入	反応タンク	終沈	放流	沈砂流入	タンク流入	反応タンク	終沈	放流	沈砂流入	タンク流入	反応タンク	終沈	放流	沈砂流入	タンク流入	反応タンク	終沈	放流	MLSS (mg/l)	RSSS (mg/l)	T1 SV (%)	T2 SV (%)	T3 SV (%)	T1 SVI	T2 SVI	T3 SVI	空気倍率	
1	日	☉			5,406	4,915																																5.6			
2	月	●	31.0	24.0	5,954	5,413	5	9	32	101	101	7.2	6.8	6.8	6.9	6.8	0.1	0.1	0.0	4.2	4.4							26.4	26.7	27.0	26.2	26.2	2,500	6,100	88	89	85	352	330	327	4.5
3	火	☉	29.0	22.0	5,606	5,097	5	9	32	101	101	7.3	6.7	6.9	7.0	6.9	0.1	0.2	0.0	3.4	4.6							25.9	26.1	26.7	26.2	26.3			87	90	88				4.5
4	水	○	31.0	23.0	5,596	5,088	3	8	28	101	101	7.4	6.9	7.0	7.1	7.1	0.1	0.9	0.0	4.2	4.9	143	60	20	7.8	7.6	25.7	26.3	26.7	26.4	26.6	2,700	4,900	87	84	86	322	300	319	4.5	
5	木	○	34.0	23.0	5,501	5,001	7	9	32	101	101	7.2	6.9	6.9	7.1	7.1	0.3	0.1	0.0	2.8	3.6							26.4	27.1	27.2	26.8	27.0			88	86	85				4.6
6	金	○	33.0	23.0	5,318	4,835	5	10	32	101	101	7.3	6.9	6.9	7.0	7.1	0.1	0.3	0.0	3.4	4.5							26.0	26.6	26.9	26.6	26.5	2,500	5,300	86	90	84	344	321	323	5.2
7	土	○			5,105	4,641																																6.1			
8	日	○			5,337	4,852																																5.7			
9	月	○	32.0	22.0	5,511	5,010	4	8	20	101	101	7.2	6.9	6.8	7.0	6.9	0.0	0.1	0.0	3.7	4.4							26.0	26.8	27.1	26.7	26.6	2,700	5,000	93	90	89	344	310	307	4.9
10	火	○	35.0	24.0	5,453	4,958	4	8	30	101	101	7.3	6.9	7.0	7.1	7.1	0.1	0.1	0.0	3.2	4.1							26.7	27.4	27.7	27.4	27.4			90	92	89				4.6
11	水	○	36.0	26.0	5,470	4,973	4	9	30	101	101	7.3	7.0	7.0	7.1	7.1	0.1	0.1	0.0	3.0	4.1							26.4	27.6	27.5	27.3	27.3	2,600	4,900	90	92	89	346	329	318	4.6
12	木	☉	34.0	26.0	5,479	4,981	4	8	32	101	101	7.4	6.9	7.0	7.1	7.1	0.1	0.1	0.0	2.4	3.1							26.6	27.2	27.3	26.9	26.9			92	93	89				4.6
13	金	○	33.0	25.0	5,421	4,929	4	8	25	101	101	7.4	6.9	7.1	7.2	7.1	0.0	0.2	0.0	3.3	4.1							26.6	27.4	27.4	27.3	27.2	2,600	4,800	90	93	89	346	332	330	4.9
14	土																																								

[illegible]