

五領川浄化センター平常試験結果

日	曜 日	天 候	気温(℃) 最高/最低		処理水量 (m3)	放流量 (m3)	透視度(cm)					pH(-)					DO(mg/l)					COD(mg/l)					水温(℃)					反応タンク								
							沈砂 流入	タン ク流 入	反応 タン ク	終沈	放流	沈砂 流入	タン ク流 入	反応 タン ク	終沈	放流	沈砂 流入	タン ク流 入	反応 タン ク	終沈	放流	沈砂 流入	タン ク流 入	反応 タン ク	終沈	放流	沈砂 流入	タン ク流 入	反応 タン ク	終沈	放流	MLSS (mg/l)	RSSS (mg/l)	T1 SV (%)	T2 SV (%)	T3 SV (%)	T1 SVI	T2 SVI	T3 SVI	空気 倍率
1	金	☉	23.0	15.0	4,545	5,225	5	8	32	101	101	7.2	6.6	6.6	6.8	6.8	0.0	0.7	0.1	3.7	4.8						22.8	23.5	23.7	22.8	22.7	2,300	8,100	96	97	95	417	388	380	5.6
2	土	●			7,810	8,267																															3.3			
3	日	○			4,738	5,477																															5.4			
4	月	○			4,844	5,271																															5.3			
5	火	○	18.0	13.0	4,629	5,331	4	7	32	101	101	7.3	6.7	6.6	6.8	6.7	7.2	0.5	0.0	3.9	4.5						22.1	22.1	22.0	21.6	21.7			94	93	92				5.5
6	水	○	18.0	11.0	4,851	5,617	6	7	27	101	101	7.3	6.4	6.8	6.9	6.8	1.0	1.6	0.2	3.5	4.4	65	57	8.4	7.4	7.4	21.6	22.1	22.6	21.6	21.6	2,400	6,100	95	95	92	396	365	383	5.3
7	木	☉	12.0	7.0	4,594	5,338	6	7	27	101	101	7.4	6.6	6.7	6.9	6.8	0.0	1.0	0.3	4.3	4.9						20.8	20.7	21.0	20.2	20.2			96	95	94				5.6
8	金	○	16.0	5.0	4,532	5,253	5	6	32	101	101	7.4	6.6	6.7	6.8	6.8	0.0	0.1	0.2	4.2	4.9						20.2	20.1	20.6	19.8	19.8	2,500	5,200	95	95	93	380	352	344	5.3
9	土	○			4,518	5,087																																4.5		
10	日	○			4,682	5,135																																4.4		
11	月	☉	21.0	12.0	4,499	5,181	5	8	32	101	101	7.4	6.7	6.9	7.0	7.0	0.0	0.0	0.1	3.1	4.3						20.8	21.0	21.1	20.8	20.7	2,600	6,100	94	95	92	362	352	329	5.3
12	火	○	20.0	11.0	4,555	5,287	5	6	25	101	101	7.2	6.6	6.8	6.9	6.9	0.0	0.4	0.1	4.1	4.6						20.5	20.5	21.0	20.2	19.8			95	96	95				5.6
13	水	○	20.0	10.0	4,555	5,279	4	6	28	101	101	7.4	6.7	6.8	7.0	7.0	0.0	1.1	0.1	3.1	4.5						21.1	21.5	21.9	20.9	21.1	2,700	5,400	90	92	90	333	329	333	5.7
14	木	○	19.0	7.0	4,551	5,291	5	7	32	101	101	7.4	6.7	6.8	6.9	7.0	0.0	0.0	0.2	4.1	5.0						20.1	19.9	20.2	19.5	1									

[illegible]