

五領川浄化センター平常試験結果

日	曜日	天候	気温(℃) 最高/最低		処理水量 (m3)	放流量 (m3)	透視度(cm)					pH(-)					DO(mg/l)					COD(mg/l)					水温(℃)					反応タンク								
							沈砂 流入	タンク 流入	反応 タンク	終沈	放流	沈砂 流入	タンク 流入	反応 タンク	終沈	放流	沈砂 流入	タンク 流入	反応 タンク	終沈	放流	沈砂 流入	タンク 流入	反応 タンク	終沈	放流	沈砂 流入	タンク 流入	反応 タンク	終沈	放流	MLSS (mg/l)	RSSS (mg/l)	T1 SV (%)	T2 SV (%)	T3 SV (%)	T1 SVI	T2 SVI	T3 SVI	空気 倍率
1	土	○			4,783	5,355																														4.1				
2	日	●			5,058	5,342																													3.9					
3	月	●	8.0	1.0	5,544	5,927	5	10	26	101	101	7.4	6.9	6.5	6.7	6.7	2.6	1.1	0.2	3.1	3.9						14.5	14.6	15.1	14.2	14.2	2,300	6,200	96	96	96	417	417	400	3.6
4	火	◎	5.0	1.0	5,303	5,768	5	7	32	101	101	7.2	6.8	6.4	6.5	6.7	3.7	1.7	0.4	3.6	4.7						13.5	13.5	13.6	13.0	12.8			96	96	95				3.8
5	水	●	7.0	3.0	5,663	6,111	6	11	32	101	101	7.4	6.9	6.5	6.6	6.7	4.1	2.7	0.2	3.4	4.4	95	52	10	8.8	9.2	13.6	14.3	14.3	14.2	14.4	2,100	6,800	96	95	95	457	413	413	3.6
6	木	◎	9.0	5.0	5,152	5,635	6	8	26	101	101	7.5	6.8	6.5	6.6	6.5	3.7	1.2	0.2	3.2	4.0						14.4	14.9	15.2	14.5	14.5			97	95	95				3.9
7	金	◎	7.0	0.0	4,941	5,458	5	7	32	101	101	7.2	6.9	6.3	6.4	6.5	3.1	1.5	1.3	3.0	3.5						14.7	14.3	17.7	13.6	13.7	2,300	5,900	96	96	96	417	400	384	4.4
8	土	◎			4,445	5,031																															4.6			
9	日	○			4,533	5,095																															4.5			
10	月	○	14.0	-1.0	4,677	5,208	5	9	32	101	101	7.5	6.9	6.5	6.6	6.4	3.3	0.6	0.9	2.7	4.1						14.1	15.2	15.2	14.8	14.4	2,500	6,300	96	96	95	384	369	352	5
11	火	●	13.0	7.0	4,583	5,149	5	8	32	101	101	7.3	6.8	6.5	6.5	6.4	2.4	1.7	0.3	3.0	4.4						15.4	15.2	15.2	14.6	14.6			96	95	98				5.5
12	水	○	19.0	5.0	4,643	5,722	6	7	32	101	101	7.3	6.8	6.2	6.4	6.6	1.8	0.0	0.4	2.9	4.1						16.2	16.9	16.8	16.0	16.0	2,500	5,700	97	94	95	388	362	352	5.4
13	木	◎	14.0	5.0	4,505	5,131	6	6	22	101	101	7.3	6.9	6.3	6.5	6.4	3.0	0.0	0.2	2.1	3.1						16.1	16.1	16.4	16.0	16.0			96	96	96				5.6
14	金	○	14.0	2.0	4,410	4,425	5	8	28	101	96	7.1	6.8	6.0	6.4	6.4	2.5	0.8	0.5	2.6	4.3																			

[illegible]