

五領川浄化センター平常試験結果

日	曜	天候	気温(℃) 最高/最低		処理水量 (m3)	放流量 (m3)	透視度(cm)					pH(-)					DO(mg/l)					COD(mg/l)					水温(℃)					反応タンク								
							沈砂 流入	タンク 流入	反応 タンク	終沈	放流	沈砂 流入	タンク 流入	反応 タンク	終沈	放流	沈砂 流入	タンク 流入	反応 タンク	終沈	放流	沈砂 流入	タンク 流入	反応 タンク	終沈	放流	沈砂 流入	タンク 流入	反応 タンク	終沈	放流	MLSS (mg/l)	RSSS (mg/l)	T1 SV (%)	T2 SV (%)	T3 SV (%)	T1 SVI	T2 SVI	T3 SVI	空気 倍率
1	日	●			4,600	5,661																																4.		
2	月	○	24.0	14.0	4,559	5,624	3	7	23	70	66	7.6	6.6	6.9	7.0	6.9	0.0	0.2	0.1	1.8	2.3						21.1	21.3	21.4	21.1	20.9	2,500	7,100	97	96	98	388	356	350	4.
3	火	●	21.0	18.0	5,021	6,042	3	5	26	86	70	7.3	6.7	6.9	7.0	7.0	0.0	0.0	0.0	2.1	2.6						20.6	21.2	21.4	20.6	20.5			97	97	95				4.
4	水	◎	23.0	14.0	4,772	5,814	5	8	25	71	73	7.6	6.8	7.0	7.0	7.0	0.2	0.7	0.0	2.1	2.9	98	59	24	10	9.8	20.8	21.3	21.5	21.1	21.2	2,300	7,200	98	98	98	426	392	377	4.
5	木	◎	26.0	13.0	4,660	5,686	5	7	26	101	81	7.7	6.8	6.9	7.0	6.9	0.0	0.2	0.3	1.9	2.4						20.9	21.2	21.5	20.9	21.1			97	98	98				5.
6	金	○	31.0	15.0	4,510	5,551	4	7	24	101	89	7.6	6.9	6.9	6.9	6.9	0.2	0.6	0.3	1.0	1.7						20.5	21.5	22.0	21.5	21.7	2,400	6,900	97	98	97	404	377	373	5.
7	土	○			4,286	5,353																																4.		
8	日	○			4,245	5,346																																4.		
9	月	○	29.0	18.0	4,518	5,552	3	7	30	101	101	7.3	6.9	6.9	7.1	6.9	0.0	0.1	0.3	1.6	1.9						21.4	22.4	22.5	22.2	22.4	2,500	7,100	98	98	97	392	363	359	5.
10	火	●	25.0	19.0	4,832	5,852	4	7	30	101	101	7.4	6.9	6.9	7.0	6.9	0.0	0.0	0.3	1.9	2.5						22.1	22.5	22.7	22.1	22.0			97	97	98				5.
11	水	●	24.0	20.0	5,080	6,119	5	9	24	101	101	7.3	6.9	6.8	6.9	6.8	0.0	0.0	0.2	2.3	2.4						21.4	21.9	22.0	21.5	21.6	2,400	7,500	98	97	98	408	388	377	
12	木	◎	25.0	17.0	4,738	5,754	4	9	20	101	101	7.4	6.9	6.8	6.9	6.9	0.2	0.3	0.1	1.9	2.2						21.9	22.1	22.3	21.8	21.9			98	97	97				5.
13	金	○	29.0	15.0	4,572	5,626	5	7	32	101	101	7.6	7.0	6.9	7.0	6.8	0.0	0.2	0.1	1.7	2.1						22.1	22.4	22.7	22.3	22.3	2,500	7,500	98	98	97	392	363	359	5.
14	土	●			4,479	5,465																																4.		
15	日	●			6,184	6,757																																3.		
16	月	○	34.0	19.0	4,987	5,948	4	11	32	101	96	7.4	6.8	6.9	7.0	6.8	0.0	0.0	0.1	1.6	2.2						22.0	22.9	23.1	22.9	22.9	2,400	7,500	98	98	98	408	392	377	4.
17	火	○	32.0	23.0	4,892	5,962	3	8	28	101	101	7.4	6.8	6.9	7.0	6.9	0.0	0.0	0.2	1.5	1.8						23.1	23.8	23.6	23.4	23.4			98	97	98				5.
18	水	○	34.0	21.0	4,830	5,880	5	10	26	101	98	7.6	6.9	6.9	7.0	7.0	0.1	0.4	0.1	1.5	2.1	113	63	11	9.4	10	22.5	23.5	23.7	23.4	23.5	2,400	7,400	98	98	98	408	392	392	4.
19	木	○	30.0	21.0	4,670	5,790	4	9	25	101	97	7.3	6.9	6.8	7.0	6.9	0.1	0.5	0.0	1.3	1.8						22.4	23.6	23.6	23.3	23.3			98	97	97				4.
20	金	○	34.0	21.0	4,575	5,631	4	8	23	101	97	7.4	6.9	6.9	7.0	7.0	0.0	0.0	0.0	1.2	1.6						23.0	24.2	24.3	24.0	24.1	2,400	7,200	98	97	97	408	388	373	4.
21	土	○			4,359	5,488																																4.		
22	日	◎			4,644	5,428																																4.		
23	月	●	28.0	21.0	6,337	7,240	2	8	27	46	55	6.9	6.9	7.0	7.1	7.0	0.0	0.1	0.2	1.3	1.5						23.0	23.3	23.4	23.1	23.1	2,300	6,900	98	98	96	426	408	436	3.
24	火	○	30.0	23.0	4,848	5,882	4	7	25	74	63	7.5	6.7	6.9	7.0	7.0	0.0	0.6	0.3	0.7	1.5						23.3	24.0	24.3	24.1	24.1			74	75	83				4.
25	水	○	31.0	24.0	4,643	5,803	5	9	18	70	69	7.5	6.9	7.0	7.0	6.9	0.2	0.1	0.1	0.9	1.2						23.6	24.6	24.4	24.2	24.2	2,400	6,700	96	96	97	400	343	346	4.
26	木	●	31.0	20.0	5,696	6,790	4	9	24	62	58	7.3	6.8	6.9	7.0	7.0	0.0	0.0	0.1	1.2	1.9						22.7	23.0	23.4	23.0	22.7			96	98	96				3.
27	金	◎	28.0	20.0	4,604	5,779	4	6	28	64	61	7.6	6.9	7.0	7.0	7.0	0.0	0.0	0.1	1.2	1.2						23.7	24.0	24.3	23.7	23.8	2,400	6,500	98	98	98	408	392	377	4.
28	土	○			4,431	5,569																																4.		
29	日	○			4,808	5,615																																3.		
30	月	○	35.0	22.0	4,736	5,764	3	9	24	44	47	7.3	6.9	7.0	7.1	7.0	0.1	0.0	0.0	1.0	1.2						23.9	24.7	24.6	24.2	24.3	2,400	6,500	98	98	97	408	363	359	

[illegible]