

五領川浄化センター平常試験結果

日	曜日	天候	気温(℃) 最高/最低		処理水量 (m3)	放流水量 (m3)	透視度(cm)					pH(-)					DO(mg/l)					COD(mg/l)					水温(℃)					反応タンク								
							沈砂 流入	タンク 流入	反応 タンク	終沈	放流	沈砂 流入	タンク 流入	反応 タンク	終沈	放流	沈砂 流入	タンク 流入	反応 タンク	終沈	放流	沈砂 流入	タンク 流入	反応 タンク	終沈	放流	沈砂 流入	タンク 流入	反応 タンク	終沈	放流	MLSS (mg/l)	RSSS (mg/l)	T1 SV (%)	T2 SV (%)	T3 SV (%)	T1 SVI	T2 SVI	T3 SVI	空気 倍率
1	火	○	34.0	25.0	4,599	5,752	3	9	23	52	50	7.2	6.7	6.9	7.1	7.0	0.0	0.1	0.0	0.9	1.7						23.2	24.4	24.4	24.0	24.0			97	98	98				4.9
2	水	☉	34.0	25.0	4,622	5,799	4	7	28	51	49	7.5	6.9	7.0	7.2	7.1	0.0	0.1	0.1	0.9	1.1	105	63	11	10	10	23.3	24.2	24.5	24.3	24.1	2,500	6,000	97	98	98	388	338	338	5.3
3	木	☉	35.0	25.0	4,538	5,780	4	7	25	50	46	7.6	7.0	6.9	7.1	7.1	0.0	0.0	0.2	0.8	1.1						23.9	25.1	25.2	24.8	24.7			97	97	98				5.4
4	金	☉	35.0	25.0	4,475	5,698	3	6	26	88	75	7.3	6.9	7.0	7.1	7.1	0.0	0.0	0.1	0.8	1.0						24.3	24.9	25.1	24.9	24.9	2,500	6,400	97	97	95	388	359	339	5.4
5	土	○			4,105	5,380																																5.9		
6	日	○			4,287	5,539																																5.7		
7	月	○	32.0	24.0	4,513	5,709	2	9	27	90	80	7.0	6.9	7.0	7.1	7.1	0.8	0.0	0.1	0.9	0.9						24.3	25.1	24.9	25.0	24.9	2,700	6,200	94	94	92	348	336	307	5.4
8	火	☉	33.0	25.0	5,277	6,426	3	6	28	101	87	7.3	6.7	7.0	7.1	7.1	0.1	0.0	0.1	0.8	0.9						24.5	25.2	25.3	25.1	25.1			96	95	96				4.6
9	水	○	35.0	26.0	4,770	5,996	5	8	28	101	82	7.6	6.8	7.0	7.1	7.1	0.0	0.9	0.1	0.7	1.4						24.5	25.2	25.1	25.0	24.9	2,400	6,400	96	97	97	400	388	346	5.1
10	木	○	34.0	25.0	5,011	5,911	5	9	25	90	70	7.5	6.9	7.0	7.1	7.1	0.0	0.1	0.1	0.6	0.9						24.2	25.7	25.8	25.4	25.4			93	96	95				4.9
11	金	☉	32.0	24.0	5,413	4,939	3	9	32	92	73	7.4	6.9	7.0	7.1	7.1	0.0	0.1	0.1	0.7	0.9						24.2	25.3	25.4	25.0	25.0	2,500	5,600	94	96	93	376	356	332	4.5
12	土	○			5,016	3,133																																4.9		
13	日	○			5,168	3,255																																4.7		
14	月	○	34.0	24.0	5,329	4,209	4	7	28	96	81	7.3	6.9	7.0	7.1	7.1	0.0	0.0	0.2																					

[illegible]