

五領川浄化センター平常試験結果

日	曜日	天候	気温(℃) 最高/最低		処理水量 (m3)	放流水量 (m3)	透視度(cm)					pH(-)					DO(mg/l)					COD(mg/l)					水温(℃)					反応タンク								
							沈砂 流入	タンク 流入	反応 タンク	終沈	放流	沈砂 流入	タンク 流入	反応 タンク	終沈	放流	沈砂 流入	タンク 流入	反応 タンク	終沈	放流	沈砂 流入	タンク 流入	反応 タンク	終沈	放流	沈砂 流入	タンク 流入	反応 タンク	終沈	放流	沈砂 流入	タンク 流入	反応 タンク	終沈	放流	MLSS (mg/l)	RSSS (mg/l)	T1 SV (%)	T2 SV (%)
1	金	○	33.0	26.0	5,166	5,472	4	11	30	82	78	7.2	6.8	7.0	7.1	7.1	0.2	0.0	0.2	0.6	0.5						26.6	27.5	27.9	27.3	27.3	2,300	5,100	95	96	90	413	369	360	4.8
2	土	○			4,938	5,298																																	5	
3	日	○			5,112	5,422																																	4.8	
4	月	○	38.0	27.0	5,425	5,508	5	10	27	95	101	7.2	6.7	6.9	7.1	7.0	0.0	0.0	0.1	0.7	0.5					27.1	27.8	27.9	27.4	27.3	2,600	5,600	95	96	95	365	356	365	4.6	
5	火	○	36.0	27.0	5,454	5,585	3	10	32	93	98	7.2	6.7	6.9	7.0	7.1	0.1	0.0	0.1	0.2	0.5					26.7	27.3	27.4	27.5	27.4			95	97	95				4.6	
6	水	☉	33.0	24.0	5,406	5,573	6	9	32	96	96	7.4	6.8	6.9	7.1	7.1	0.0	0.0	0.1	0.6	0.6					26.7	27.2	27.5	27.1	27.1	2,300	5,200	94	96	93	409	384	372	4.6	
7	木	●	30.0	23.0	5,632	5,832	4	9	25	92	91	7.3	6.8	6.9	7.1	7.1	0.2	0.0	0.2	0.6	0.7	105	61	13	9.2	9.2	25.9	26.1	26.4	26.2	26.1			92	95	93				4.4
8	金	☉	32.0	24.0	5,248	5,514	5	9	23	101	98	7.3	6.8	6.8	7.0	6.9	0.0	0.0	0.2	0.2	0.4					26.3	26.8	27.0	26.7	26.6	2,300	4,900	94	94	89	409	392	356	4.8	
9	土	○			5,146	5,265																																4.9		
10	日	○			5,778	5,728																																4.3		
11	月	●			6,059	5,939																																4.1		
12	火	●	29.0	25.0	5,688	5,846	5	8	32	101	101	7.4	6.6	6.8	6.9	6.8	0.0	0.0	0.1	0.3	0.6					25.2	25.8	25.8	25.7	25.5			92	95	93				4.4	
13	水	☉	31.0	22.0	5,282	5,521	6	9	30	101	101	7.1	6.6	6.8	6.9	6.9	0.0	0.0	0.1	0.5	0.6					25.8	26.1	26.4	26.1	26.1	2,400	4,900	93	94	95	388	362	365	4.7	
14	木	○	33.0	24.0	5,223	5,504	5	8	28	101	101	7.2	6.7	6.9	7.1	7.0	0.0	0.0	0.2	0.5	0.5					25.5	26.0	26.1	26.0											

[illegible]