

五領川浄化センター平常試験結果

日	曜日	天候	気温(℃) 最高/最低		処理水量 (m3)	放流水量 (m3)	透視度(cm)					pH(-)					DO(mg/l)					COD(mg/l)					水温(℃)					反応タンク								
							沈砂流入	タンク流入	反応タンク	終沈	放流	沈砂流入	タンク流入	反応タンク	終沈	放流	沈砂流入	タンク流入	反応タンク	終沈	放流	沈砂流入	タンク流入	反応タンク	終沈	放流	沈砂流入	タンク流入	反応タンク	終沈	放流	MLSS (mg/l)	RSSS (mg/l)	T1 SV (%)	T2 SV (%)	T3 SV (%)	T1 SVI	T2 SVI	T3 SVI	空気倍率
1	月	○	34.0	26.0	5,371	5,654	5	11	32	101	101	7.3	6.8	7.0	7.1	7.1	0.0	0.0	0.2	0.4	0.4						26.8	27.0	27.2	27.5	27.4	2,500	5,100	95	97	96	380	373	369	4.6
2	火	○	36.0	27.0	5,356	5,612	4	9	32	101	101	7.4	6.8	7.0	7.1	7.1	0.1	0.0	0.1	0.4	0.4						27.2	28.0	28.0	28.0	28.4			94	94	90				4.7
3	水	○	32.0	23.0	5,230	5,599	5	10	32	101	101	7.5	6.9	7.0	7.2	7.2	0.2	0.1	0.1	0.5	0.5	105	61	10	8.8	8.8	26.5	26.5	27.3	27.1	27.7	2,100	4,200	92	94	90	438	409	391	4.8
4	木	○	33.0	25.0	5,398	5,777	4	10	32	101	101	7.3	6.9	7.0	7.0	7.0	0.0	0.0	0.2	0.1	0.2						27.0	27.6	27.7	27.2	27.5			90	91	89				4.6
5	金	●	30.0	24.0	5,229	5,625	4	8	32	101	101	7.3	6.9	7.0	7.0	7.0	0.0	0.0	0.2	0.2	0.3						26.1	26.7	26.9	26.7	26.8	2,200	4,600	92	93	90	418	404	391	4.7
6	土	○			4,732	5,247																																	5.3	
7	日	○			4,981	5,333																																	5.1	
8	月	●	31.0	26.0	5,508	5,821	2	8	32	101	101	6.9	6.8	6.9	7.1	7.0	0.0	0.0	0.2	0.2	0.3						26.2	26.6	26.8	26.4	26.4	2,400	4,600	91	94	90	379	376	360	5.3
9	火	○	34.0	24.0	5,219	5,651	3	7	32	101	101	7.4	6.8	6.9	7.1	7.0	0.0	0.0	0.2	0.2	0.2						26.2	26.8	27.2	27.1	27.0			96	94	91				4.9
10	水	○	33.0	25.0	5,227	5,681	4	8	32	101	101	7.4	6.8	6.9	7.0	7.0	0.0	0.0	0.3	0.2	0.3						26.4	27.0	27.2	27.0	27.2	2,200	4,400	94	94	85	427	392	340	4.8
11	木	◎	30.0	23.0	5,225	5,638	5	9	32	101	100	7.4	6.8	6.8	7.1	6.9	0.0	0.0	0.3	0.1	0.2						25.7	26.2	26.2	25.8	25.9			90	92	91				4.8
12	金	◎	32.0	24.0	5,008	5,472	5	9	32	101	101	7.3	6.9	6.8	7.0	6.9	0.0	0.0	0.3	0.3	0.1						26.1	26.5	26.5	26.5	26.5	2,200	4,300	90	93	91	409	388	396	4.8
13	土	◎			4,599	5,178																																	5.3	
14	日	●			5,507																																			

[illegible]