

五領川浄化センター平常試験結果

日	曜日	天候	気温(℃) 最高/最低		処理水量 (m3)	放流水量 (m3)	透視度(cm)					pH(-)					DO(mg/l)					COD(mg/l)					水温(℃)					反応タンク								
							沈砂 流入	タンク 流入	反応 タンク	終沈	放流	沈砂 流入	タンク 流入	反応 タンク	終沈	放流	沈砂 流入	タンク 流入	反応 タンク	終沈	放流	沈砂 流入	タンク 流入	反応 タンク	終沈	放流	沈砂 流入	タンク 流入	反応 タンク	終沈	放流	沈砂 流入	タンク 流入	反応 タンク	終沈	放流	MLSS (mg/l)	RSSS (mg/l)	T1 SV (%)	T2 SV (%)
1	水	○	28.0	18.0	5,529	5,998	4	8	25	101	101	7.2	6.7	6.9	7.0	7.0	0.1	0.1	0.6	3.6	4.3						24.9	25.8	26.0	25.7	25.7	2,500	6,000	90	91	90	360	350	360	4.6
2	木	○	27.0	16.0	5,358	5,842	5	10	32	101	91	7.4	6.8	6.9	7.0	7.0	0.0	0.0	0.4	2.2	3.4						24.7	25.2	25.3	25.2	25.2			91	92	90				4.8
3	金	◎	29.0	17.0	5,118	5,653	4	9	32	101	101	7.4	6.8	6.8	7.0	7.1	0.4	0.4	0.3	3.7	4.4						25.2	24.9	25.4	24.4	24.3	2,600	4,800	94	92	90	362	368	346	5
4	土	●			5,191	5,786																																	5	
5	日	●			5,796	6,379																																	4.4	
6	月	○	28.0	20.0	5,789	6,289	5	9	30	101	101	7.3	6.7	6.8	7.0	6.9	0.2	0.1	0.2	3.7	4.6						25.0	25.3	25.5	25.0	24.9	2,500	5,500	95	94	93	380	362	358	4.4
7	火	◎	29.0	17.0	5,454	5,932	5	8	25	101	92	7.4	6.5	6.8	7.0	6.1	0.0	0.0	1.1	2.5	3.6						24.6	24.9	24.9	24.8	24.8			93	94	93				4.7
8	水	◎	28.0	21.0	5,331	5,868	5	8	23	98	98	7.2	6.6	6.8	7.0	6.9	0.0	0.1	1.1	2.6	3.3						24.8	25.6	25.7	25.4	25.4	2,600	5,100	92	90	90	354	346	333	4.8
9	木	○	26.0	19.0	5,261	5,817	5	9	20	89	82	7.4	6.6	6.9	7.1	7.1	0.0	1.2	0.6	4.3	5.0	128	60	13	10	10	24.8	25.5	25.8	25.2	25.2			96	94	92				4.9
10	金	○	25.0	14.0	5,077	5,304	5	8	28	98	91	7.4	6.6	6.8	7.0	7.0	0.0	0.0	0.4	2.7	3.6						24.4	24.9	25.0	24.8	24.8	2,600	5,200	94	92	94	362	341	336	5.4
11	土	●			4,661	4,554																																	5.6	
12	日	○			4,660	4,541																																	5.5	
13	月	○			4,897	4,748																																	5.3	
14	火	◎	22.0	18.0	5,705	5,340	4	7	23	101	89	7.3	6.6	6.8	7.0	6.9	0.0	0.0	0.2	2.6	3.0						25.2													

[illegible]