

五領川浄化センター平常試験結果

日	曜日	天候	気温(℃) 最高/最低		処理水量 (m3)	放流水量 (m3)	透視度(cm)					pH(-)					DO(mg/l)					COD(mg/l)					水温(℃)					反応タンク								
							沈砂流入	タンク流入	反応タンク	終沈	放流	沈砂流入	タンク流入	反応タンク	終沈	放流	沈砂流入	タンク流入	反応タンク	終沈	放流	沈砂流入	タンク流入	反応タンク	終沈	放流	沈砂流入	タンク流入	反応タンク	終沈	放流	MLSS (mg/l)	RSSS (mg/l)	T1 SV (%)	T2 SV (%)	T3 SV (%)	T1 SVI	T2 SVI	T3 SVI	空気倍率
1	木	*			5,491	3,539																																3.7		
2	金	*			5,815	3,866																															3.5			
3	土	*			5,812	3,840																															3.5			
4	日	●			5,894	3,898																															3.5			
5	月	●	6.0	-1.0	6,416	4,276	6	8	32	101	101	7.2	7.0	6.7	6.8	6.6	3.6	0.2	0.3	5.0	6.1						14.4	14.7	15.3	14.4	14.4	2,600	5,400	92	93	92	354	344	329	3.2
6	火	●	6.0	-1.0	5,993	3,940	6	8	32	101	101	7.4	6.6	6.7	6.8	6.7	2.8	0.2	0.3	4.7	6.0						15.4	15.3	15.4	15.0	15.3			92	92	94				3.5
7	水	○	11.0	0.0	6,110	3,885	6	9	32	101	101	7.4	6.9	6.7	6.9	6.9	2.7	0.2	0.1	4.3	5.9						15.7	15.5	15.6	15.2	15.2	2,600	5,200	93	93	93	358	358	332	3.4
8	木	●	6.0	0.0	7,563	4,976	5	13	32	101	101	7.3	6.9	6.6	6.8	6.9	3.5	2.3	0.5	4.0	5.3	90	48	7.2	7.2	7.8	15.0	14.8	15.6	15.2	15.3			88	90	88				2.7
9	金	○	6.0	1.0	6,037	3,928	6	9	32	101	101	7.4	6.9	6.6	6.6	6.5	3.4	0.8	0.5	3.3	4.8						15.2	15.1	15.6	14.9	15.2	2,500	5,400	92	93	92	368	372	329	3.5
10	土	○			5,836	3,526																																3.5		
11	日	●			6,138	3,706																																3.4		
12	月	*			6,810	4,170																																3		
13	火	●	10.0	2.0	6,823	4,453	6	9	32	101	101	7.4	6.7	6.6	6.7	6.5	2.3	1.1	0.5	3.3	4.7						15.2	15.4	16.0	15.3	15.3			94	94	92				3
14	水	●	5.0	1.0	6,748	4,454	6	10	32	101	101	7.3	6.8	6.6	6.7	6.9	3.0	1.2	0.5	4.1	4.8						15.2	14.6	14.7	14.7	14.3	2,500	6,100	93	94	92	372	362	329	3.1
15	木	○	11.0	1.0	6,002	3,927	6	10	32	101	101	7.7	6.9	6.6	6.6	6.6	2.4	0.4	0.1	4.1	4.8						15.8	15.6	16.0	15.0	14.6			93	93	92				3.4

[illegible]