

五領川浄化センター平常試験結果

温度(℃) /最低	処理水量 (m3)	放流量 (m3)	透視度(cm)					pH(-)					DO(mg/l)					COD(mg/l)					水温(℃)					反応タンク								
			沈砂 流入	タンク 流入	反応 タンク	終沈	放流	沈砂 流入	タンク 流入	反応 タンク	終沈	放流	沈砂 流入	タンク 流入	反応 タンク	終沈	放流	沈砂 流入	タンク 流入	反応 タンク	終沈	放流	沈砂 流入	タンク 流入	反応 タンク	終沈	放流	MLSS (mg/l)	RSSS (mg/l)	T1 SV (%)	T2 SV (%)	T3 SV (%)	T1 SVI	T2 SVI	T3 SVI	空気 倍率
9.0	5,285	4,186	5	8	32	101	96	7.3	6.8	6.5	6.7	6.7	1.7	0.8	0.2	4.5	5.2						18.8	19.0	19.2	18.5	18.4	2,900	6,600	97	96	97	334	331	313	4.9
8.0	5,317	4,214	5	8	32	101	101	7.2	6.6	6.5	6.7	6.6	0.4	0.3	0.2	4.2	6.0						19.4	19.3	19.5	18.4	18.3			97	98	97				4.2
3.0	5,579	4,454	6	8	23	101	101	7.1	6.8	6.8	7.0	6.9	1.1	2.0	0.2	5.0	6.1	123	57	14	9.4	9.8	19.6	19.4	19.8	19.0	19.3	2,700	6,400	95	96	98	352	356	338	3.6
1.0	6,217	4,896	6	7	21	101	101	7.4	6.7	6.7	6.9	6.9	1.7	1.9	0.1	4.8	4.7						17.1	16.4	16.7	17.0	16.5			95	97	95				3.3
2.0	6,935	5,212	5	6	21	101	86	7.6	6.9	6.9	7.1	7.0	1.7	1.1	0.2	4.7	5.7						18.0	17.9	18.4	16.4	16.6	2,700	7,100	96	94	94	356	336	336	2.9
	5,382	3,608																																		3.8
	5,289	3,537																																		3.8
5.0	5,640	3,651	4	6	30	101	97	7.2	6.6	6.7	6.9	6.7	0.2	0.2	0.2	3.8	5.1						18.3	18.7	18.9	18.1	18.2	2,700	6,200	94	94	97	348	348	334	3.6
4.0	5,727	3,711	6	10	32	101	101	7.6	6.8	6.9	7.0	6.9	1.1	1.8	0.3	4.5	5.6						18.6	18.3	18.8	18.3	18.1			96	94	94				3.6
5.0	5,643	3,698	4	8	32	101	100	7.4	6.9	6.9	7.0	6.9	0.0	0.4	0.2	4.4	5.5						18.9	19.3	19.1	17.4	17.5	2,600	6,500	95	97	95	365	359	339	3.6
4.0	5,901	3,821	7	9	32	101	85	7.4	7.0	7.0	7.0	7.0	1.4	1.8	0.2	4.1	5.5						18.2	17.5	18.0	17.7	17.8			95	95	94				3.4
2.0	5,591	3,615	4	10	30	101	92	7.4	6.9	6.8	6.8	6.9	1.3	0.7	0.0	4.2	5.3						18.5	18.1	18.0	17.0	16.8	2,500	7,700	93	94	94	372	362	348	4.2
	5,084	3,376																																		4
	5,783	3,910																																		3.5
4.0	5,790	3,891	6	10	32	101	101	7.5	7.0	6.8	6.9	6.8	0.0	0.4	0.2	5.0	5.4						18.4	18.4	18.6	18.1	17.8</									

[illegible]