

令和8年4月分

五領川浄化センター平常試験結果

令和08年05月28日

日	曜	天候	気温(℃) 最高/最低		処理水量 (m3)	放流量 (m3)	透視度(cm)					pH(-)					DO(mg/l)					COD(mg/l)					水温(℃)					反応タンク								
							沈砂 流入	タンク 流入	反応 タンク	終沈	放流	沈砂 流入	タンク 流入	反応 タンク	終沈	放流	沈砂 流入	タンク 流入	反応 タンク	終沈	放流	沈砂 流入	タンク 流入	反応 タンク	終沈	放流	沈砂 流入	タンク 流入	反応 タンク	終沈	放流	MLSS (mg/l)	RSSS (mg/l)	T1 SV (%)	T2 SV (%)	T3 SV (%)	T1 SVI	T2 SVI	T3 SVI	空気 倍率
1	水	○	13.0	10.0	5,332	3,645	5	8	25	101	101	7.4	6.9	6.7	6.9	6.9	1.4	2.0	1.1	3.7	5.5	95	61	13	8.0	8.8	16.8	17.4	17.5	17.3	16.9	2,400	4,200	90	89	89	375	356	371	3
2	木	●	14.0	8.0	5,712	4,232	5	8	25	95	83	7.8	7.3	6.8	7.0	7.0	3.0	0.6	1.1	3.8	4.1						18.3	18.0	18.5	17.8	17.9			90	90	87				3
3	金	○	19.0	5.0	5,221	3,843	5	8	18	95	81	7.5	6.7	6.7	6.9	6.8	0.1	0.1	1.1	3.5	4.8						17.2	17.8	18.0	17.5	17.4	2,300	4,500	91	92	90	396	383	375	3
4	土	●			4,913	3,643																																	4	
5	日	○			5,238	3,895																																	3	
6	月	○	25.0	10.0	5,310	3,817	5	9	32	100	96	7.4	7.8	6.8	6.9	6.9	0.0	0.2	1.0	3.4	4.3						18.0	18.8	18.4	17.9	18.0	2,400	4,800	94	94	92	392	362	368	3
7	火	●	18.0	8.0	5,393	3,899	4	7	32	95	83	7.3	6.8	6.8	6.9	6.9	0.2	0.2	1.7	3.6	4.8						17.5	17.4	17.5	17.6	17.5			93	94	90				3
8	水	◎	15.0	7.0	5,430	4,024	5	8	32	98	82	7.7	6.9	6.7	6.8	6.8	0.1	0.0	1.4	3.2	4.2						17.7	17.9	18.2	17.7	17.7	2,400	4,200	94	92	90	392	383	375	3
9	木	○	19.0	8.0	5,477	4,064	5	7	32	100	87	7.7	7.0	6.8	6.8	6.9	1.1	0.6	1.5	5.9	4.2						17.5	18.2	18.4	17.6	17.7			91	92	90				3
10	金	●	19.0	13.0	6,955	5,239	5	7	25	101	98	7.6	6.9	6.7	6.9	6.9	0.5	0.1	1.1	2.6	3.9						19.4	19.6	19.9	19.2	19.1	2,100	5,700	90	90	89	429	409	371	2
11	土	○			5,340	4,069																																	3	
12	日	○			5,329	4,043																																	3	
13	月	○	23.0	8.0	5,957	4,091	4	8	26	101	101	7.3	6.9	6.7	6.7	6.9	3.5	0.1	1.0	3.6	4.6						17.9	18.5	18.4	17.9	18.1	2,300	4,100	93	93	91	404	388	379	3
14	火	○	22.0	9.0	6,006	4,168	4	9	32	101	101	7.8	6.9	6.8	6.9	6.9	0.1	0.2	1.2	3.7	4.7						18.1	18.7	18.6	18.3	18.2			93	94	91				3
15	水	●	19.0	13.0	6,177	4,360	6	7	27	101	100	7.5	6.9	6.8	6.8	6.6	0.0	0.1	1.0	3.2	5.8						18.6	19.3	19.2	18.7	18.8	2,300	4,100	91	93	93	396	388	388	3
16	木	○	18.0	10.0	5,982	4,271	6	10	32	101	101	7.6	6.9	6.8	6.9	6.9	0.2	0.1	0.9	3.3	4.6						18.5	18.9	18.8	18.3	18.3			92	94	91				3
17	金	○	23.0	9.0	5,674	4,033	4	9	32	101	101	7.8	6.9	6.7	6.8	6.8	0.0	0.1	0.8	2.5	3.6						18.3	19.0	19.1	18.8	18.8	2,200	4,800	92	92	94	418	400	392	3
18	土	○			5,624	3,850																																	3	
19	日	○			5,839	3,998																																	3	
20	月	○	25.0	14.0	5,585	4,115	4	8	28	101	101	7.3	6.9	6.8	6.9	6.8	0.0	0.2	0.9	3.4	4.2						19.0	19.8	19.9	19.7	19.8	2,100	5,000	96	95	96	457	432	417	3
21	火	○	20.0	8.0	5,904	4,470	5	7	30	101	101	7.3	6.8	6.8	6.9	6.9	0.0	0.2	1.2	3.6	4.7						18.8	19.1	19.3	18.8	18.7			95	95	94				3
22	水	○	24.0	7.0	5,701	4,277	5	8	21	101	101	7.6	7.0	6.8	6.9	7.0	0.4	1.9	0.9	4.1	5.2	108	58	11	8.4	8.4	18.4	19.1	19.3	19.6	19.4	2,200	5,000	94	94	93	427	392	404	3
23	木	●	16.0	12.0	6,222	4,725	5	10	20	101	101	7.7	6.9	6.8	6.9	6.8	0.0	0.2	1.1	3.0	4.1						18.9	18.9	19.0	18.8	18.8			93	94	90				3
24	金	○	19.0	11.0	5,764	4,374	4	8	25	101	101	7.6	6.9	6.7	6.9	6.8	0.2	0.1	0.9	4.0	5.0						18.7	19.1	19.3	18.8	18.7	2,200	4,700	94	92	93	427	418	404	3
25	土	○			5,347	4,099																																	3	
26	日	○			5,341	4,114																																	3	
27	月	◎	18.0	11.0	6,161	4,313	4	6	30	101	101	7.2	6.8	6.7	6.9	6.8	0.3	0.1	0.8	3.7	4.2						18.7	19.1	19.4	19.1	19.1	2,100	5,300	94	95	92	448	452	438	3
28	火	○	26.0	12.0	5,570	3,999	5	10	23	101	101	7.3	6.8	6.8	6.9	6.9	0.2	0.1	0.8	3.4	4.7						19.6	20.0	20.0	19.5	19.4			96	95	94				3
29	水	◎			5,408	3,885																																	3	
30	木	○	19.0	11.0	5,663	4,164	5	8	32	101	101	7.4	6.9	6.7	6.7	6.8	0.0	0.1	0.9	3.6	4.4						18.7	18.9	19.0	18.6	18.8			97	95	94				3

[illegible]