

五領川浄化センター平常試験結果

日	曜日	天候	気温(℃) 最高/最低		処理水量 (m3)	放流水量 (m3)	透視度(cm)					pH(-)					DO(mg/l)					COD(mg/l)					水温(℃)					反応タンク								
							沈砂 流入	タンク 流入	反応 タンク	終沈	放流	沈砂 流入	タンク 流入	反応 タンク	終沈	放流	沈砂 流入	タンク 流入	反応 タンク	終沈	放流	沈砂 流入	タンク 流入	反応 タンク	終沈	放流	沈砂 流入	タンク 流入	反応 タンク	終沈	放流	MLSS (mg/l)	RSSS (mg/l)	T1 SV (%)	T2 SV (%)	T3 SV (%)	T1 SVI	T2 SVI	T3 SVI	空気 倍率
1	金	●	22.0	12.0	6,643	4,205	5	8	32	101	101	7.4	6.8	6.8	6.7	6.9	0.1	0.0	0.9	3.1	4.6						19.1	19.5	19.7	19.3	19.4	2,300	4,700	94	95	94	409	413	392	3
2	土	○			6,331	4,431																																3.2		
3	日	◎			5,331	4,104																															3.8			
4	月	●			6,182	4,764																															3.3			
5	火	○			5,339	4,111																															3.9			
6	水	○			5,703	4,183																															3.6			
7	木	◎	25.0	14.0	5,797	4,402	5	8	23	101	100	7.4	6.7	6.8	6.9	6.9	0.1	0.7	1.1	4.5	5.3	105	57	10	8.4	8.4	19.1	19.8	20.0	20.0	20.2			94	93	92				3.5
8	金	◎	22.0	13.0	5,647	4,364	5	10	23	101	101	7.2	6.7	6.8	6.9	6.9	0.0	0.1	1.0	3.1	4.5						19.6	20.3	20.3	19.9	20.1	2,400	5,200	95	94	94	396	409	392	3.6
9	土	○			5,322	4,156																																3.9		
10	日	○			5,407	4,231																																3.8		
11	月	○	27.0	12.0	5,673	4,441	5	8	32	101	101	7.3	6.8	6.8	6.9	6.9	0.1	0.1	0.7	2.9	4.3						19.8	20.4	20.5	20.1	20.3	2,400	5,300	95	96	95	396	400	365	3.6
12	火	◎	26.0	15.0	5,717	4,457	4	8	32	93	98	7.2	6.5	6.7	6.7	6.9	0.1	0.2	0.8	2.7	4.0						20.3	20.8	20.8	20.4	20.6			94	90	95				3.6
13	水	◎	25.0	14.0	5,688	4,467	5	8	25	101	101	7.6	6.8	6.9	7.0	6.9	0.0	0.2	0.8	3.4	4.0						20.4	21.2	21.1	20.8	20.9	2,400	5,400	94	95	95	392	413	380	3.6
14	木	○	22.0	14.0	5,701	4,479	5	9	30	101	101	7.4	6.7	6.9	7.0	7.0	0.1	0.2	0.8	3.2	4.4						20.7	21.2	21.2	20.9	20.8			96	96	94				3.6
15	金	○	22.0	15.0	5,485	4,332	6	8	30	90	85	7.4	6.8	6.9	7.0	7.0	0.1	0.0	0.8	2.5	3.5						20.7	21.0	20.9</											

[illegible]