

五領川浄化センター平常試験結果

日	曜日	天候	気温(℃) 最高/最低		処理水量 (m3)	放流水量 (m3)	透視度(cm)					pH(-)					DO(mg/l)					COD(mg/l)					水温(℃)					反応タンク								
							沈砂 流入	タンク 流入	反応 タンク	終沈	放流	沈砂 流入	タンク 流入	反応 タンク	終沈	放流	沈砂 流入	タンク 流入	反応 タンク	終沈	放流	沈砂 流入	タンク 流入	反応 タンク	終沈	放流	沈砂 流入	タンク 流入	反応 タンク	終沈	放流	沈砂 流入	タンク 流入	反応 タンク	終沈	放流	MLSS (mg/l)	RSSS (mg/l)	T1 SV (%)	T2 SV (%)
1	水	○	28.0	21.0	5,990	4,460	5	8	32	101	101	7.2	6.8	6.9	7.0	6.9	0.0	0.0	0.6	2.1	2.9						24.1	24.5	24.5	24.2	24.3	2,500	4,600	96	95	95	384	365	352	4.1
2	木	●	24.0	20.0	7,470	6,325	5	8	32	101	101	7.5	6.9	6.9	7.0	7.0	0.1	0.0	0.7	2.7	3.3					23.9	23.9	24.1	24.0	23.7			92	89	90				3.3	
3	金	○	25.0	19.0	6,007	5,276	6	8	32	101	101	7.4	6.9	6.8	7.0	6.8	0.0	0.0	0.5	3.9	4.2					23.9	24.0	24.1	23.8	23.7	2,500	5,400	93	93	92	372	372	368	4.1	
4	土	◎			5,544	4,520																																4.5		
5	日	○			6,069	4,603																																4.1		
6	月	●	29.0	21.0	6,561	5,223	5	7	32	101	101	7.2	6.9	6.8	6.9	6.8	0.1	0.0	0.6	2.2	3.0					23.3	23.4	23.6	23.1	23.2	2,500	6,500	93	91	90	372	364	360	3.8	
7	火	○	31.0	21.0	5,923	5,021	4	8	32	101	101	7.1	6.7	6.8	7.0	6.9	0.1	0.0	0.6	2.4	2.9					24.4	24.7	24.8	24.6	24.6			94	93	91				4.2	
8	水	○	33.0	24.0	5,859	4,916	5	8	26	101	101	7.3	6.9	6.9	7.1	7.0	0.2	0.5	0.6	2.9	3.5	105	56	9.2	7.6	7.4	23.2	24.0	24.0	24.1	24.0	2,500	5,400	97	95	95	388	365	365	4.2
9	木	○	34.0	23.0	5,718	4,910	4	10	28	101	101	7.4	6.8	6.9	7.0	6.9	0.3	0.1	0.5	2.3	3.0					23.8	24.6	24.6	24.5	24.5			95	96	94				4.2	
10	金	○	34.0	23.0	5,574	4,530	4	8	32	101	101	7.1	6.8	6.9	7.0	6.9	0.0	0.0	1.1	2.2	3.0					24.1	24.8	24.7	24.7	24.6	2,700	5,200	94	95	94	348	365	348	4.4	
11	土	○			5,642	4,441																																4.4		
12	日	○			5,650	4,554																																4.3		
13	月	●	30.0	25.0	5,591	4,487	4	9	32	101	101	6.9	6.8	6.8	7.0	6.9	0.1	0.0	0.8	2.3	2.5					24.2	24.9	24.9	24.6	24.6	2,700	4,700	97	97	94	359	359	324	4.4	
14	火	○	32.0	24.0	5,601	5,020	4	7	32	101	101	7.1																												

[illegible]